

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE0006

In compliance with *Regulation 305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Arrow 600 Series electrically powered hold open & free swing Door Closer (Size 3 to 4)

Intended use:- For use on fire rated single leaf and double leaf doors

STANDARD DOOR MOUNT PULL SIDE APPLICATION. Essential characteristics Harmonised technical Performance specification Test ref's: 141262,141262/F,141262/P, 141262/FP, 141481, WIL 327223, WIL 327386 & 138941. Ability to release 5.1.2 release from any angle Pass 5.1.3 Not possible to inhibit the Pass release 5.1.4 Supply voltage Pass 5.1.5 External electrical connection Pass 5.1.6 Inlet for external wiring Pass 5.2.1 General 5.2.2 Electrical release Pass EN 1155:1997+A1:2002/AC:2006 requirements 5.2.4 Durability Pass 5.2.5 Angle of hold open Pass 5.2.6 Manual release Pass 5.2.7 Continuous hold open Pass NPD 5.2.8 Overload performance 5.2.9 Delayed release NPD 5.2.10 Electrical performance Pass 5.1.11 Temperature Rise Pass 5.1.12 Damage Pass 5.1.13 Fire / smoke doors Grade 1 **Essential characteristics** Harmonised technical Performance specification Durability of Ability to release 5.2.14.1 corrosion Grade 3 (96 hours) 5.2.14.2 corrosion Pass If a reference to dangerous substances is added Dangerous Substances EN 1155:1997+A1:2002/AC:2006 in the table ZA.1, the following claim is suggested: Annex ZA3 Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations



Certificate of Constancy of Performance

2812-CPR-AE0006

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Arrow 600 Series electrically powered hold open & freeswing Door Closer (Size 3)

Intended use:- For use on fire rated single leaf and double leaf doors

PARALLEL ARM APPLICATION.

| Essential characteristics | Performance | Harmonised technical |
|--------------------------------------|---|------------------------------|
| | Fenomance | specification |
| | | specification |
| Ability to release | D | |
| 5.1.2 release from any angle | Pass | |
| 5.1.3 Not possible to inhibit the | | |
| release | Pass | |
| 5.1.4 Supply voltage | Pass | |
| 5.1.5 External electrical connection | Pass | |
| 5.1.6 Inlet for external wiring | Pass | |
| | | |
| 5.2.1 General | | |
| 5.2.2 Electrical release | Pass | |
| | | EN 1155:1997+A1:2002/AC:2006 |
| requirements | | |
| 5.2.4 Durability | Pass | |
| 5.2.5 Angle of hold open | Pass | |
| 5.2.6 Manual release | Pass | |
| 5.2.7 Continuous hold open | Pass | |
| 5.2.8 Overload performance | NPD | |
| 5.2.9 Delayed release | NPD | |
| 5.2.10 Electrical performance | Pass | |
| 5.1.11 Temperature Rise | Pass | |
| 5.1.12 Damage | Pass | |
| 5.1.13 Fire / smoke doors | Grade 1 | |
| Essential characteristics | Performance | Harmonised technical |
| Essential characteristics | renormance | specification |
| | | specification |
| Durability of Ability to release | | |
| 5.2.14.1 corrosion | Grade 3 (96 hours) | |
| 5.2.14.2 corrosion | Pass | |
| | | |
| Dangerous Substances | If a reference to dangerous substances is added | EN 1155:1997+A1:2002/AC:2006 |
| Annex ZA3 | in the table ZA.1, the following claim is suggested: Pass: the materials in the closer do not contain or | |
| | release any dangerous substances in excess of | |
| | the maximum levels specified in existing European | |
| | material standards or any national regulations | |
| | | |



Certificate of Constancy of Performance

2812-CPR-AE0006

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Arrow 600 Series electrically powered hold open & freeswing Door Closer (Size 4)

Intended use:- For use on fire rated single leaf and double leaf doors

TRANSOM MOUNT PUSH SIDE APPLICATION.

| Essential characteristics | Performance | Harmonised technical |
|---|---|------------------------------|
| | | specification |
| Ability to release | | |
| 5.1.2 release from any angle | Pass | |
| 5.1.3 Not possible to inhibit the | | |
| release | Pass | |
| 5.1.4 Supply voltage | Pass | |
| 5.1.5 External electrical connection | Pass | |
| 5.1.6 Inlet for external wiring | Pass | |
| 5.2.1 General 5.2.2 Electrical release | Pass | |
| | | EN 1155:1997+A1:2002/AC:2006 |
| requirements | Dava | |
| 5.2.4 Durability | Pass | |
| 5.2.5 Angle of hold open | Pass | |
| 5.2.6 Manual release | Pass | |
| 5.2.7 Continuous hold open | Pass | |
| 5.2.8 Overload performance | NPD | |
| 5.2.9 Delayed release | NPD | |
| 5.2.10 Electrical performance | Pass | |
| 5.1.11 Temperature Rise | Pass Pass | |
| 5.1.12 Damage | | |
| 5.1.13 Fire / smoke doors | Grade 1 | Harmonised technical |
| Essential characteristics | Performance | specification |
| Durability of Ability to release | | |
| 5.2.14.1 corrosion | Grade 3 (96 hours) | |
| 5.2.14.2 corrosion | Pass | |
| | | |
| Dangerous Substances | If a reference to dangerous substances is added | EN 1155:1997+A1:2002/AC:2006 |
| Annex ZA3 | in the table ZA.1, the following claim is suggested: Pass: the materials in the closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | |
| | | <u> </u> |



Certificate of Constancy of Performance

2812-CPR-AE0006

Placed on the Market under the Name of

Arrow Architectural Ltd Tything Road, Arden Forest Industrial Estate, Alcester, Warwickshire. B49 6ES

and produced in the manufacturing plant

E/019

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 15/12/2020 and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: 14/12/2023

ERO Project Reference: EROWF11264



Paul Duggan Certification Manager



CSF408-NL 5.0